

# Risk Assessment Methodologies for US Army Corps of Engineers Civil Works Infrastructure

Presentation to the Pipeline Risk Model Work Group

Robert C. Patev

National Risk Advisor

Risk Management Center

USACE

[robert.c.patev@usace.army.mil](mailto:robert.c.patev@usace.army.mil)



US Army Corps of Engineers  
**BUILDING STRONG®**



# TOPICS

- Background on USACE
- Risk Assessment Methodologies
  - ▶ Major Rehabilitation Program
  - ▶ Dam Safety Program
  - ▶ Levee Safety Program
  - ▶ Asset Management Program
- Conclusions



# USACE Mission Areas

**BUILDING STRONG – USACE Supports the Army and the Nation**



**USACE Has a Diverse Mission Set Driven by Diverse Customers**

Source: MG Jackson – OPM





# Civil Works Value to the Nation



- Every \$1 spent on Flood Risk Management prevented nearly \$8 in flood damages (Both adjusted for inflation)
  - 709 dams; 14,700 miles of levees; 400 miles of shoreline protection
- 183 major ports (250K+ tons of commerce), 884 smaller harbors
  - 12,000 miles of commercial inland waterways
- Marine transportation supports \$1 trillion in commerce and 13,000,000 jobs annually
  - Environmental restoration
- Response to 17 Presidentially declared disasters (2015)
- Largest US outdoor recreation program – 370 million visits a year
  - Stewardship of 11.7 million acres of public lands
- 75 hydropower plants produce 3% of US electric energy
  - Water supply: 6.9 billion gallons per day
  - Nearly \$4.9 B in contracts to private business



***“The Nation’s security depends on its economic strength, and its economic strength depends on its infrastructure”***

10

Source: MG Jackson – OPM



# I am a dam.

I am many things to many people.

## I am a protector.

I keep floodwaters off many communities.

## I am a water supply.

Many towns count on me for their water needs.

## I am a recreational facility.

I provide areas where people from all over come to swim, fish and camp.

## I am an employer.

I create jobs for many communities.

## I am an economic boost.

The tourism dollars I generate are spread throughout the local area.

## I am a power plant.

Some of us help produce electricity for your homes and businesses.

## I am a sanctuary.

I provide a habitat for fish, bird and wildlife species.

## I am a navigation manager.

River traffic depends on me for navigable water levels.

## I am a tourist attraction.

People come from miles around to see me in action.

## I am yours.

I am part of the Corps of Engineers' Civil Works Infrastructure.

*MULTIPLE Corps "Business Lines," and more, provide Value and benefits and influenced by investments in a single asset!*

***"Knowing the assets contribution to value"***



**BUILDING STRONG®**

# Major Rehabilitation

- Major Rehabilitation (MR) Program
  - ▶ MR process started in USACE in early 1990's
    - Joint effort between engineering, planning and operations
  - ▶ MR still in usage today by many USACE Districts
    - Widely applied to number of USACE projects over the past 25 years
    - Future increase in number of projects performing MR in FY15.





# Major Rehab Authorization

- **WATER RESOURCES DEVELOPMENT ACT OF 1992**

- ▶ **Section 205 - DEFINITION OF REHABILITATION FOR INLAND WATERWAY PROJECTS.**

- Pub. L. 102–580, title II, § 205, Oct. 31, 1992,
- 106 Stat. 4827
- 33 USC 2327
  - ▷ Title 33 - NAVIGATION AND NAVIGABLE WATERS
  - ▷ CHAPTER 36 - WATER RESOURCES DEVELOPMENT
  - ▷ SUBCHAPTER V - GENERAL PROVISIONS
  - ▷ Sec. 2327 - Definition of rehabilitation for inland waterway projects



# Major Rehabilitation for USACE Projects

- Engineering Pamphlet (EP) 1130-2-500
  - ▶ Dated - 27 Dec 1996
  - ▶ CECW-O - Operations policy document
    - Rehabilitation Evaluation and Report preparation will be funded under the Operation and Maintenance, General, appropriation
    - Major Rehabilitation Construction, funded out of Construction, General appropriation
    - 3 year budget cycle submission for CG funds





# Major Rehabilitation for USACE Projects

- Engineering Pamphlet (EP) 1130-2-500
  - ▶ Chapter 3 – Major Rehabilitation Program
    - Purpose, Background and Guidance
  - ▶ Appendix B – Rehabilitation Evaluation Report
  - ▶ Appendix C – Conceptual Approach for Analyzing Rehabilitation
  - ▶ Appendix D – Introduction to Assessment of Structural Reliability
  - ▶ Appendix E – Benefit Evaluation Procedures
  - ▶ Appendix F – Example of Combining Risks and Consequences



# EC 1110-2-6062



US Army Corps  
of Engineers®

ENGINEERING AND DESIGN

EC 1110-2-6062  
1 February 2011

## Risk and Reliability Engineering for Major Rehabilitation Studies

CECW-CE

Circular  
No. 1110-2-6062

DEPARTMENT OF THE ARMY  
U.S. Army Corps of Engineers  
Washington, DC 20314-1000

EC 1110-2-6062

1 February 2011

### EXPIRES 31 JANUARY 2013 Engineering and Design RISK AND RELIABILITY ENGINEERING FOR MAJOR REHABILITATION STUDIES

1. Purpose. This Engineer Circular (EC) presents comprehensive guidance for engineering risk and reliability for Major Rehabilitation studies. This EC includes the methods for developing engineering reliability applications. It covers applications for multiple engineering disciplines. Although there is discussion of economic consequences from unreliable performance, the focus of this EC is on predicting engineering performance, not on the economics of investment decisions. A fuller treatment of risk assessment to inform the major rehabilitation investment decisions will be developed while this EC is used as interim guidance.

2. Applicability. This circular is applicable to all USACE commands having responsibility for the major rehabilitation studies.

3. Distribution Statement. Approved for public release; distribution is unlimited.

4. References. References are at Appendix A.

5. Discussion. The use of probabilistic analytical methods, including the development of hazard functions, is a relatively new concept within USACE. In the last 15 years, the use of probabilistic and risk-based methods has become an acceptable and required analysis technique for USACE studies. Most of the historical use of engineering reliability analysis within USACE has included the development and utilization of hazard functions for major rehabilitation studies, systems studies, and evaluation of the need for new navigation projects when the existing structure is in a deteriorated condition.

FOR THE COMMANDER:

JAME C. DALTON, P.E., SES  
Chief, Engineering and Construction Division  
Directorate of Civil Works

4 Appendices  
Appendix A – References  
Appendix B – Navigation Reliability  
Appendix C – Flood Control Reliability  
Appendix D – Hydropower Reliability



# Major Rehab Process

- Assemble PDT – PM, Engineering, Environmental, Economist, Cost, etc...
- Document Project History
  - ▶ Current and historical
    - Condition
    - Poor performance
    - Maintenance – annual and emergency
    - Cost of repairs
    - Etc....





# Major Rehab Process

- Failure Modes Effects and Criticality Analysis (FMECA)
- Establish Base Condition
  - ▶ “Fix as Fails”
  - ▶ Used as measuring stick against all alternatives
- Perform Reliability Analysis
  - ▶ Estimate PUP or hazard rate (time-dependent) using reliability models



# Reliability Methods

- Two ways to estimate reliability for Major Rehabilitation Studies:
  - ▶ Non-Probabilistic
  - ▶ Probabilistic



## ■ Non-Probabilistic Reliability Methods

- ▶ Historical Frequency of Occurrence
- ▶ Survivorship Curves (hydropower equipment)
- ▶ Expert Opinion Elicitation





## ■ Historical Frequencies

- ▶ Use of known historical information for records at site to estimate the failure rates of various components
- ▶ For example, if you had 5 hydraulic pumps in standby mode and each ran for 2000 hours in standby and 3 failed during standby. The failure rate during standby mode is:

$$\begin{aligned}\text{Total standby hours} &= 5(2000 \text{ hours}) &&= 10,000 \text{ hours} \\ \text{Failure rate in standby mode} &&&= 3 / 10,000 \\ &&&= 0.0003 \text{ failures per hour}\end{aligned}$$



## ■ Manufacturers' survivorship/mortality curves

- ▶ Curves are available from manufacturers' for different motors, pumps, electrical components, etc...
- ▶ Curves are developed from field data and “failed” components
  - Caution is to be exercised on mode of failure
  - Failure data may have to be censored
- ▶ However, usually this data is not readily available for equipment at Corps projects except mainly hydropower facilities
- ▶ Report available at IWR on hydropower survivorship curve as well as many textbooks on the subject



## ■ Expert Opinion Elicitation (EOE)

- ▶ Solicitation of “experts” to assist in determining probabilities of unsatisfactory performance or rates of occurrence.
- ▶ Need proper guidance and assistance to solicit and train the experts properly to remove all bias and dominance.
- ▶ Should be documented well for ATR/IEPR
- ▶ Used frequently when limit states are not easily defined and data is poor
- ▶ Used commonly in Dam and Levee Safety Risk Assessments






- Probabilistic Reliability Methods
  - Reliability Index ( $\beta$ ) Methods
    - ▷ First Order Second Moment (Taylor Series)
    - ▷ Advanced Second Moment (Hasofer-Lind)
    - ▷ Point Estimate Method
  - Monte Carlo Simulation
  - Time-Dependent (Hazard Functions)
  - Response Surface Modeling



## ■ Hazard Functions

### ► Degradation of Structures

- Relationship of **strength (R) (capacity)** vs. load (S) (demand)




## ■ Hazard Function (conditional failure rate)

► Developed for the ORMSSS economists/planners to assist in performing their economic simulation analysis for ORMSSS investment decisions

►  $h(t) = P[\text{fail in } (t, t+dt) | \text{survived } (0, t)]$

►  $h(t) = f(t) / L(t)$   
= No. of failures in t  
No. of survivors up to t



**BUILDING STRONG®**



# Event Trees

- Used in many engineering applications for risk assessments
  - ▶ Risk
    - Probability of Failure
    - Consequences
  - ▶ Probability of events
  - ▶ Developed by engineers with input from economists



# Dashields Guard Wall Event Tree

Anchor Wall Prior to Failure  
\$2,000,000 / 3 Days of Closure

| Load Case                          | Applied | Model Results             | Repair Level                     | Repair Level Consequences<br>Cost/Closure |              | Future Reliability                     |
|------------------------------------|---------|---------------------------|----------------------------------|---|--------------|--|
|                                    |         |                           |                                  |   |              |  |
| Impact 10%                         |         | Unsat. Perform. 14.34%    | Minor Damage 60%                 | 5 Days                                    | \$350,000    | No Change                              |
|                                    |         |                           | Repair Damaged Areas             |   |              |  |
|                                    |         |                           | Significant Damage 35%           | 15 Days                                   | \$700,000    | R = 1.0 for remainder<br>of life cycle |
|                                    |         |                           | Make Repairs and Anchor Wall     | 5 Days                                    | 2,50,0000    |  |
|                                    |         |                           | Wall Section Completely Fails 5% | 60 Days                                   | \$10,000,000 | R = 1.0 for remainder<br>of life cycle |
| No Barge Load 70%                  |         | No Unsat. Perform. 85.66% | Replace Wall Section and Anchor  |   |              |  |
|                                    |         |                           |                                  |   |              |  |
|                                    |         |                           |                                  |   |              |  |
| Dashields<br>Guide Wall Event Tree |         | Unsat. Perform. 0%        |                                  |   |              |  |
|                                    |         |                           |                                  |   |              |  |
|                                    |         |                           |                                  |   |              |  |
| Hawser Pull 20%                    |         | No Unsat. Perform. 100%   |                                  |   |              |  |
|                                    |         |                           |                                  |   |              |  |
|                                    |         |                           |                                  |   |              |  |

**BUILDING**

# Major Rehab Process

- Economic simulations
  - ▶ Determine BCR and NED
    - Base Condition
      - ▷ Uses PUP from Engineering
    - With Rehabilitation
      - ▷ Alternatives
      - ▷ Advanced maintenance or scheduled repair or maintenance strategies.





# Dam Safety Program

- ER 1110-2-1156 – Safety of Dams (2014)

|   |   |                |
|---|---|----------------|
| CECW-CE   | DEPARTMENT OF THE ARMY<br>US Army Corps of Engineers<br>Washington, DC 20314-1000 | ER 1110-2-1156 |
| Regulation<br>No. 1110-2-1156   |   | 31 March 2014  |
| Engineering and Design<br>SAFETY OF DAMS – POLICY AND PROCEDURES                  |   |                |
| TABLE OF CONTENTS   |   |                |
|   | <u>Paragraph</u>  | <u>Page</u>    |
| Summary of Changes  |   | xix            |
| Chapter 1. Dam Safety Program - Introduction, Overview,<br>and Guiding Principles |   |                |
| Purpose   | 1.1   | 1-1            |
| Applicability   | 1.2   | 1-1            |
| Distribution Statement  | 1.3   | 1-1            |
| References  | 1.4   | 1-1            |
| Classroom   | 1.5   | 1-1            |





# Dam Safety Program

- Dam Safety Assurance Program (~1996)
  - ▶ Follow on to Major Rehab Program
  - ▶ Probabilistic Risk Assessments
    - Loading – Flood or seismic
    - Fragility - utilize similar reliability methods from Major Rehab program
    - Consequences – damage to property or life loss
  - ▶ Flood Risk Management projects put into Major Rehab cue for funding



# Dam Safety Program

- Screening Portfolio Risk Assessment (2003-2007)
  - ▶ Examined USACE portfolio of ~620 flood control and navigation dams
  - ▶ Relative risk method
    - Loading ranges established for flood and seismic loads
    - Used base rate adjustment for critical failure modes
      - ▷ Base rates adjusted by four descriptors (A, PA, PI, I)
    - Consequences for load events



## Engineering Rating Summary

| Feature<br>Navigation High Head Dam              | Normal Water<br>Level | 50%<br>Exceedence<br>Duration<br>Water Level<br>with OBE | 50%<br>Exceedence<br>Duration<br>Water Level<br>with MDE | Unusual<br>(100yr) | Extreme<br>(PMF) |
|--|-----------------------|--|--|--------------------|------------------|
| <b>Concrete Structures – Rock Foundation</b>     |                       |  |  |                    |                  |
| External Stability                               | I                     | PA   | PI   | I                  | I                |
| Internal Stability                               | I                     | PA   | PI   | I                  | I                |
| Foundation Stability – under dam                 | PA                    | A  | A  | PA                 | PA               |
| Scour Protection                                 | PA                    | A  | A  | PA                 | PA               |
| Foundation -Seepage & Piping                     | PA                    | A  | A  | PA                 | PA               |
| Abutment Foundation Stability                    | A                     | A  | A  | A                  | A                |
| <b>Concrete Structures – Pile Foundation</b>     |                       |  |  |                    |                  |
| Foundation Seepage & Piping (Incl. upstream cut) | NA                    | NA   | NA   | NA                 | NA               |
| Foundation Liquefaction                          | NA                    | NA   | NA   | NA                 | NA               |
| External Stability1                              | NA                    | NA   | NA   | NA                 | NA               |
| Foundation Stability (Incl. pile capacity) 1     | NA                    | NA   | NA   | NA                 | NA               |
| Internal Stability                               | NA                    | NA   | NA   | NA                 | NA               |
| Scour Protection                                 | NA                    | NA   | NA   | NA                 | NA               |
| .....Void.....                                   | NA                    | NA   | NA   | NA                 | NA               |
| Abutment Foundation Stability1                   | NA                    | NA   | NA   | NA                 | NA               |
| <b>Gates &amp; Gate Structure</b>                |                       |  |  |                    |                  |
| Spillway gate(s) failure 2                       | I                     | PA   | PA   | I                  | I                |
| Spillway gate piers – structural capacity        | PA                    | A  | PA   | PA                 | PA               |
| Gates – Electrical/Mechanical                    | A                     | A  | PA   | A                  | PA               |
| Lock gates (struct/elect/mech)                   | I                     | PA   | PI   | I                  | I                |
| .....Void.....                                   | NA                    | NA   | NA   | NA                 | NA               |
| <b>Embankment &amp; Closure Dikes</b>            |                       |  |  |                    |                  |
| Embankment Seepage & Piping                      | PA                    | A  | A  | PA                 | PA               |
| Embankment Stability and/or Liquefaction         | A                     | A  | PA   | A                  | A                |
| Erosion: Toe, Surface & Crest                    | A                     | A  | A  | A                  | PA               |
| Abutments Seepage & Piping                       | A                     | A  | A  | A                  | A                |
| Abutments Stability and/or Liquefaction          | A                     | A  | A  | A                  | A                |
| Foundation Seepage & Piping                      | A                     | A  | A  | A                  | A                |
| Foundation Stability and/or Liquefaction         | A                     | A  | A  | A                  | A                |
| <b>Emergency Closure Systems</b>                 |                       |  |  |                    |                  |
| Service bridge,                                  | A                     | A  | PA   | A                  | A                |
| Crane & Power                                    | A                     | A  | PA   | A                  | A                |
| Bulkheads  | PI                    | A  | A  | A                  | A                |
| .....Void.....                                   | NA                    | NA   | NA   | NA                 | NA               |
| <b>Other Features</b>                            |                       |  |  |                    |                  |
| Feature 1  | A                     | A  | PA   | A                  | PA               |
| Feature 2  | NA                    | NA   | NA   | NA                 | NA               |
| Feature 3  | NA                    | NA   | NA   | NA                 | NA               |
| Feature 4  | NA                    | NA   | NA   | NA                 | NA               |

## Definition of Engineering Ratings

|    |                     |        |  |
|----|---------------------|--------|--|
| A  | Adequate            | = 1    | confidence backed up by data, studies, or obvious project characteristics and judged to meet current engineering standards and criteria. |
| PA | Probably Adequate   | = 10   | and may not specifically meet criteria. Requires additional investigation or studies to confirm adequacy.                                |
| PI | Probably Inadequate | = 100  | confidence and requires additional studies and investigations to confirm. Judged to not meet current criteria.                           |
| I  | Inadequate          | = 1000 | confidence. Physical signs of distress are present. Analysis indicates factor of safety near limit state.                                |
| NA | Not Applicable      | = 0    | Feature does not exist   |




**BUILDING STRONG®**

# Dam Safety Program

- ER 1156 Risk Assessment Methodology
  - ▶ Potential Failure Mode Analysis (PFMA)
    - Evaluate and Describe Potential Failure Modes
  - ▶ Construct Event Trees to Analytically Describe the Potential Path to Failure
  - ▶ Use Expert Elicitation with an Experienced Facilitator to Evaluate Relative Likelihoods of Each Event Tree Branch
  - ▶ Use the Analysis to Develop a Rational Case to Support a Decision
  - ▶ Examine tolerable risk curves (Farmer's Curves)



# Risk Assessment Framework





| Event Information   |   |
|---|---|
| <b>Loading Condition:</b>   | Hydrologic  |
| <b>Failure Mode:</b>  | Overtopping Erosion of the Levee  |
| <b>Location:</b>  | Low Areas based on Survey Results   |
| <b>Event and Initiator:</b>   | Very Large Flood with Possible Debris Blockage at Bridges   |
| Influence Factors   |   |
| More Likely (Adverse)   | Less Likely (Favorable)   |
| Expect there to be more debris at large flood flows than has been seen in the past  | Needs close to SPF to trigger (overtop) without debris blockage   |
| Trestle bridge has closely spaced supports which are more likely to catch debris  | Except for trestle bridge, bridge piers are typically widely spaced   |
| Bridge decks may catch debris at high flow since they are typically close to the levee crest  | Backwater at bridges due to debris would be of limited extent upstream  |
| Some areas of the levee would overtop at SPF without debris blockage by up to 1 to 2 feet   | Small area near DART line most susceptible (lowest crest), could be sand bagged (1,000 to 2,000 feet)   |
| Largest peak storm is a flashy local thunderstorm occurring between the upstream reservoirs and the levee – may not have much time to react | Could attempt to deal with debris at bridges using backhoes or other equipment  |
| Local inundation of the exit roadways may hinder evacuation   | Fairly confident in hydraulic model and predicted water surface profile, so should have relatively good idea when overtopping will occur (with no debris) |
| Vulnerable population (hospitals, nursing homes, etc.) may need assistance to evacuate  | Short distance to safety – the inundated areas will be relatively close to the river, evacuation to upper floors of buildings possible                    |
|   | EAP would likely be initiated for event like this which would lead to early evacuations   |
|   | Short duration of overtopping may not breach levee – hydrographs indicate peak flows may not be long duration   |


**Likelihood Category:** Low to Moderate      **Confidence:** Moderate



**Rationale:** Although it is likely the levee embankments would overtop during a flood equal to the Standard Project Flood (SPF) or greater, the compacted clay soils of the embankments will likely survive some level of overtopping without breach. The main uncertainty had to do with the possible duration of overtopping at large floods similar to the SPF that would overtop the dam.



**BUILDING STRONG®**

# Event Trees






# Dam Safety Program

- Semi-Quantitative Risk Assessment (SQRA)
  - ▶ Screening level approach but more rigor than SPRA
  - ▶ Risk matrix approach to examining probability of failures and consequences
  - ▶ Uses PFMA to estimate probability of failure
  - ▶ Uses rough estimates for consequences (loss of life and direct economic loss)



# SQRA



| Unit/<br>Reach  | PFM  | Failure<br>Likelihood | Confidence | Incremental<br>Loss of Life       | Confidence | Economic Loss        | Confidence |
|-----------------|--|-----------------------|------------|-----------------------------------|------------|----------------------|------------|
| Unit 2<br>A-2/I | PFM 11 – Backwards erosion<br>piping in foundation               | High                  | Low        | Very High to<br>Extremely<br>High | Moderate   | High to Very<br>High | Moderate   |
| Unit 2<br>I     | PFM 1 – Overtopping with<br>breach                               | Low                   | Low        | Very High to<br>Extremely<br>High | Moderate   | High to Very<br>High | Moderate   |
| Unit 2<br>I     | PFM 16 – Concentrated leak<br>erosion along pipe<br>penetrations | Remote                | Moderate   | Very High to<br>Extremely<br>High | Moderate   | High to Very<br>High | Moderate   |





# Dam Safety Program

- Event driven process – flood or seismic
- PFMA does not look at consequences or criticality directly
- Relies on Expert Opinion Elicitation for ET nodes
  - ▶ Kent Tables for descriptors and probabilities
  - ▶ No probabilistic methods
- Does not include time dependency
- Does not include uncertainty
- Does not include operational risks





# Levee Safety Program

- ER 1120-2-XXXX Safety of Levees (guidance still under development)
- Reliability of levees were was first developed under the Major Rehabilitation Program in 1990's
  - ▶ Developed reliability models for levees and floodwalls (Taylor Series Finite Difference)
  - ▶ Examined consequences (property damage but not life loss) of levee failures



# Hurricane Katrina – Aug 2005



Overtopping along Gulf Intracoastal Waterways



**BUILDING STRONG®**



# Hurricane Katrina – Aug 2005



17<sup>th</sup> Street Canal Breach



**BUILDING STRONG®**



# Hurricane Katrina – Aug 2005



London Avenue Canal North Near the Robert E. Lee Bridge




**BUILDING STRONG®**

# Interagency Performance Evaluation Task (IPET) Force

...“to provide credible and objective scientific and engineering answers....”

Chief of Engineers



**THE NATIONAL ACADEMIES**  
*Advisers to the Nation on Science, Engineering, and Medicine*

<https://ipet.wes.army.mil>


[NOLArisk.usace.army.mil](http://NOLArisk.usace.army.mil)

# IPET Risk Assessment



- IPET Background
- Risk Assessment Model
- Hazard
- System Identification
- Reliability Modeling
- Risk Analysis
- Uncertainty
- Validation
- Lesson Learned



# Risk Assessment




# Hazard Analysis



## Storm Modeling

- ADCIRC
- Historic storms in parameter set
  - 100± Low Res Runs
  - 1800± Med Res Runs
  - 60± High Res Runs
  - Frequency Analysis
- Calibrate (HWM & Storm Team Results)
  - Add Waves







# System Performance

**Orleans Main Basin  
100 Year Elevations**

NAVD88 (EPOCH 2004.65) Feet




**Elevations consider  
expected sea level rise,  
subsidence and settlement**





# Event Tree




# Before Katrina, you had a 1% chance every year of flooding this deep from Hurricanes


## Notes:

- The water surface elevations are mean values
- The scale sensitivity of the legend is +/- 2 feet
- The info does not depict interior drainage modeling results
- The storm surge is characterized as the result of a probabilistic analysis of 5 to 6 storm parameters of a suite of 152 storms and not a particular event

**Assumes 0% Pumping Capacity**




# Consequences




**Stage-loss relationships  
for Pre-Katrina  
population and property**

New Orleans Area HPS with  
Polder and Sub-Polders

OM Stage-Fatality



OM Stage-Damage






# Loss of Life Risk Maps

## (Pre-K Population and Property)

Hurricane Protection System in place before Katrina with no pumping  
There was a 1% (1 in 100) chance for this number of fatalities

**Pre-Katrina, 100-year, 0% pump**



Hurricane Protection System in place in June 2007 with no pumping  
There was a 1% (1 in 100) chance for this number of fatalities

**2007, 100-year, 0% pump**




100-Year Hurricane Protection System with no pumping  
There is a 1% (1 in 100) chance for this number of fatalities

**2011, 100-year, 0% pump**




Hurricane Protection System in place before Katrina with pumping at 50% of capacity  
There was a 1% (1 in 100) chance for this number of fatalities

**Pre-Katrina, 100-year, 50% pump**




Hurricane Protection System in place in June 2007 with pumping at 50% of capacity  
There was a 1% (1 in 100) chance for this number of fatalities

**2007, 100-year, 50% pump**



100-Year Hurricane Protection System with pumping at 50% of capacity  
There is a 1% (1 in 100) chance for this number of fatalities


**2011, 100-year, 50% pump**



# Economic 1% Risk Maps (Pre-K Population and Property)


Hurricane Protection System in place before Katrina with no pumping  
There was a 1% (1 in 100) chance of this percentage property loss

**Pre-Katrina, 100-year, 0% Pump**



Hurricane Protection System in place in June 2007 with no pumping  
There was a 1% (1 in 100) chance of this percentage property loss

**2007, 100-year, 0% Pump**




100-Year Hurricane Protection System with no pumping  
There is a 1% (1 in 100) chance of this percentage property loss

**2011, 100-Year, 0% Pump**




Hurricane Protection System in place before Katrina with pumping at 50% of capacity  
There was a 1% (1 in 100) chance of this percentage property loss

**Pre-Katrina, 100-year, 50% Pump**



Hurricane Protection System in place in June 2007 with pumping at 50% of capacity  
There was a 1% (1 in 100) chance of this percentage property loss

**2007, 100-Year, 50% Pump**



100-Year Hurricane Protection System with pumping at 50% of capacity  
There is a 1% (1 in 100) chance of this percentage property loss

**2011, 100-Year, 50% Pump**



**PAST**

**PRESENT**

**FUTURE**



**BUILDING STRONG®**

# Levee Screening Tool (2009)

- Used to rank levees in terms of Levee Safety Action Classification (LSAC) ratings and prioritization for future risk assessments
- Base failure rate for critical performance modes for levees and floodwalls
- Base rate adjustment made using Bayesian techniques and three likelihood modifiers (A, M, U)






**Table 2.1 Performance Modes and Related Inspection Items**

| Performance Mode                             | Inspection Item Category | Inspection Item Number | Inspection Item Name                                   |
|--|--------------------------|------------------------|--|
| Embankment and Foundation Seepage and Piping | Levees                   | 1                      | Unwanted Vegetation Growth                             |
|  | Levees                   | 3                      | Encroachments  |
|  | Levees                   | 7                      | Settlement   |
|  | Levees                   | 9                      | Cracking   |
|  | Levees                   | 10                     | Animal Control   |
|  | Levees                   | 11                     | Culverts / Discharge Pipes                             |
|  | Levees                   | 14                     | Under Seepage Relief Wells / Toe Drainage Systems      |
|  | Levees                   | 15                     | Seepage  |
| Embankment Stability                         | Levees                   | 3                      | Encroachments  |
|  | Levees                   | 5                      | Slope Stability  |
|  | Levees                   | 7                      | Settlement   |
|  | Levees                   | 8                      | Depressions / Rutting                                  |
|  | Levees                   | 9                      | Cracking   |
|  | Levees                   | 14                     | Underseepage Relief Wells / Toe Drainage Systems       |
| Embankment Erosion                           | Levees                   | 2                      | Sod Cover  |
|  | Levees                   | 6                      | Erosion / Bank Caving                                  |
|  | Levees                   | 12                     | Riprap Revetments and Bank Protection                  |
|  | Levees                   | 13                     | Revetments other than Riprap                           |
| Closure Systems                              | Levees / Floodwalls      | 4 / 3                  | Closure Systems  |
| Floodwall Stability                          | Floodwalls               | 1                      | Unwanted Vegetation Growth                             |
|  | Floodwalls               | 2                      | Encroachments  |
|  | Floodwalls               | 4                      | Concrete Surfaces                                      |
|  | Floodwalls               | 5                      | Tilting, Sliding, or Settlement of Concrete Structures |
|  | Floodwalls               | 6                      | Foundation of Concrete Structures                      |
|  | Floodwalls               | 8                      | Underseepage Relief Wells / Toe Drainage Systems       |
| Floodwall Underseepage and Piping            | Floodwalls               | 1                      | Unwanted Vegetation Growth                             |
|  | Floodwalls               | 2                      | Encroachments  |
|  | Floodwalls               | 8                      | Underseepage Relief Wells / Toe Drainage Systems       |
|  | Floodwalls               | 9                      | Seepage  |
|  | n / a                    | n / a                  | Culverts / Discharge Pipes                             |



# Levee Screening Tool

Conditional Performance Index Summary



# Levee Safety Program

- Current Risk Assessment Methodology
  - ▶ Potential Failure Mode Analysis (PFMA)
    - Evaluate and Describe Potential Failure Modes
  - ▶ Construct Event Trees to Analytically Describe the Potential Path to Failure
  - ▶ Use Expert Elicitation with an Experienced Facilitator to Evaluate Relative Likelihoods of Each Event Tree Branch
  - ▶ Use the Analysis to Develop a Rational Case to Support a Decision
  - ▶ Use tolerable risk guidelines (Farmer's curves)



# Levee Safety Program

- Semi-Quantitative Risk Assessment (SQRA)
  - ▶ Screening level approach but more rigor than SPRA
  - ▶ Risk matrix approach to examining probability of failures and consequences
  - ▶ Uses PFMA to estimate probability of failure
  - ▶ Uses rough estimates for consequences (loss of life and direct economic loss)



# Levee Safety Program

- Event driven process – flood or seismic
- PFMA does not look at consequences or criticality directly
- Relies on Expert Opinion Elicitation for ET nodes
  - ▶ Kent Tables of descriptors and probabilities
  - ▶ No probabilistic methods
- Does not include time dependency
- Does not include uncertainty








# Asset Management

- USACE AM program started in 2006
- Program is developed to support risk-informed decision making and prioritization of USACE Operations and Maintenance budget work packages (~14,000 work packages a year, ~\$2B)
- AM looks at and across all USACE business lines
- AM focuses on value and utility of each work package



# USACE Asset Management




*What, where and when do I invest? Providing "Line of Sight" to enable the assets greatest **Value** to the Nation!*




BUILDING STRONG®




# Lifecycle Portfolio Management Process




# Lifecycle Portfolio Management Process



# Lifecycle Portfolio Management Process




# Lifecycle Portfolio Management Process



**BUILDING STRONG®**



# Lifecycle Portfolio Management Process



# Operational Risk Assessment

Risk = Probability of Failure X Consequences

## ➤ 5x5 Relative Risk Matrices

- Currently available in Budget EC
- Known limitations – based on one consequence

## ➤ Prototype ORA Workbook tool for Nav Locks & Dams

- OCA data, probability of failure for components, economic impacts
- Started with FY13 budget development

## ➤ Hydropower Modernization Initiative (HMI)

- Used to help plan non-BPA capital investments

## ➤ Other BL's – No Risk Assessment tool



# 5x5 Risk Matrix

TABLE D-5 Relative Risk Value Matrix (1-25 Matrix)

|  |   |             | Relative Risk Value Matrix (1-25 Matrix)      |            |                     |                   |          |
|--|---|-------------|---|------------|---------------------|-------------------|----------|
| <div> <div>Condition</div> <div>Consequence</div> </div> |   |             | FRM Project Condition Tool (Illustration D.1) |            |                     |                   |          |
|  |   |             | F (1)   | D (2)      | C (3)               | B (4)             | A (5)    |
|  |   |             | Failed  | Inadequate | Probably Inadequate | Probably Adequate | Adequate |
| Consequence Category                                     | 1 | High        | 1   | 2          | 6                   | 10                | 15       |
|  | 2 | Medium High | 3   | 5          | 9                   | 14                | 19       |
|  | 3 | Medium      | 4   | 8          | 13                  | 18                | 22       |
|  | 4 | Low         | 7   | 12         | 17                  | 21                | 24       |
|  | 5 | Minimal     | 11  | 16         | 20                  | 23                | 25       |

|  |                        |
|--|------------------------|
|  | High Relative Risk     |
|  | Med-High Relative Risk |
|  | Medium Relative Risk   |
|  | Low Relative Risk      |
|  | Minimal Relative Risk  |



# 5x5 Risk Matrix - OCA & Consequences

TABLE D-3. Condition Assessment Standards for Sub-Features

| Condition Classification        | Definitions  |
|---------------------------------|--|
| <b>A</b><br>Adequate            | 1) Component is fully functional,<br>2) No documented critical design flaw in terms of structural/operational capacity or functionality,<br>3) No documented or observed deficiencies by definition,<br>4) No indication of wear.  |
| <b>B</b><br>Probably Adequate   | 1) Component is fully functional,<br>2) No documented critical design flaw in terms of structural/operational capacity or functionality,<br>3) Documentation, testimonies and/or observations concluded that a deficiency by definition exists,<br>4) A clear mode of failure cannot be confirmed,<br>5) The components performance is not affected by the deficiency,<br>6) The feature mission requirement(s) (i.e. flood control, water quality, water supply, etc.) are not affected by the deficiency,<br>7) Normal operating procedures and routine maintenance requirements are not affected by the deficiency. 8) Safety of personnel and end users are not affected by the deficiency.<br>9) There are indications of normal wear as documented, reported or observed.  |
| <b>C</b><br>Probably Inadequate | 1) Component is fully functional,<br>2) A critical design flaw potentially exist in terms of structural/operational capacity or functionality, but must be further substantiated by owning District,<br>3) Documentation, testimonies and/or observations conclude that a deficiency by definition exists,<br>4) Documentation, testimonies, and/or observation can confirm a progressing degradation of the components condition,<br>5) A clear mode of failure cannot be confirmed,<br>6) The components performance is not presently affected by the deficiency, but is likely due to the substantiated progress in degradation,<br>7) The feature mission requirement(s) (i.e. flood control, water quality, water supply, etc.) are not presently affected by the deficiency, but likely due to the substantiated progress in degradation,<br>8) Normal operating procedures and routine maintenance requirement are not presently affected by the deficiency, but likely due to the substantiated progress in degradation,<br>9) Safety of personnel and end users not presently affected by the deficiency.   |
| <b>D</b><br>Inadequate          | 1) Component is functional,<br>2) Documentation, testimonies and/or observations conclude that a deficiency by definition exists,<br>3) Documentation, testimonies, and/or observation can confirm that the deficiency is significant by any of the following criteria:<br>a. A clear mode of failure exists,<br>b. The components performance is presently affected,<br>c. Feature mission requirement(s) (i.e. flood control, water quality, water supply, etc.) are presently affected,<br>d. Normal operating procedures are presently affected,<br>e. Routine maintenance requirements are presently affected,<br>4) A recent unsatisfactory performance or failure of service due to the deficiency cannot be confirmed by documentation or testimonies,<br>5) It is not likely that an imminent failure of the component will occur, 6) A critical life safety concern to personnel or end users does not exist.  |
| <b>E</b><br>Failing or Failed   | Failing:<br>1) Component is functional,<br>2) Documentation, testimonies and/or observations conclude that a deficiency by definition exists,<br>3) Documentation, testimonies, and/or observation can confirm that the deficiency is significant by any of the following criteria:<br>a. A clear mode of failure exists,<br>b. The components performance is presently affected,<br>c. Feature mission requirement(s) (i.e. flood control, water quality, water supply, etc.) are presently affected,<br>d. Normal operating procedures are presently affected,<br>e. Routine maintenance requirements are presently affected,<br>4) In addition to the affect the deficiency has on performance and operation, a recent unsatisfactory performance or failure of service due to the deficiency can be confirmed by documentation or testimonies,<br>5) In addition to the affect the deficiency has on performance and operation, it is likely that an imminent failure of the component will occur,<br>6) In addition to the affect the deficiency has on performance and operation, a critical life safety concern to personnel or end users exists.<br>Failed:<br>Component is unsatisfactory or failure cannot be confirmed. |


“Or” logic – can only use 1 consequence

| Consequence Category 1 Rating Criteria  | Category Rating |
|---|-----------------|
| <b>PAR:</b> PAR $\geq$ 100,000  | 1               |
| 50,000 $\leq$ PAR $<$ 100,000   | 2               |
| 25,000 $\leq$ PAR $<$ 50,000  | 3               |
| 10,000 $\leq$ PAR $<$ 25,000  | 4               |
| PAR $<$ 10,000  | 5               |
| Consequence Category 2 Rating Criteria  | Category Rating |
| <b>Economic Impact:</b> Damages to residential and nonresidential structures, their contents, and vehicles greater than \$10B | 1               |
| Damages to residential and nonresidential structures, their contents, and vehicles ranging from \$1B to \$10B                 | 2               |
| Damages to residential and nonresidential structures, their contents, and vehicles ranging from \$100M to \$1B                | 3               |
| Damages to residential and nonresidential structures, their contents, and vehicles ranging from \$10M to \$100M               | 4               |
| Damages to residential and nonresidential structures, their contents, and vehicles less than \$10M                            | 5               |
| Consequence Category 3 Rating Criteria  | Category Rating |
| <b>Environmental:</b> Permanent loss of nationally scarce habitat   | 1               |
| Permanent impacts to Federal listed threatened or endangered species and their designated critical habitat                    | 2               |
| Permanent loss of regionally scarce, or declining aquatic and/or associated habitats  | 3               |
| Temporary adverse impacts to all designated special status species and habitat  | 4               |
| Insignificant loss of scarce habitat; no effect on special status species   | 5               |
| Consequence Category 4 Rating Criteria  | Category Rating |
| <b>Critical Infrastructure:</b> Ratio of Essential Structures Damaged $\geq$ 30%  | 1               |
| 25% $\leq$ Ratio of Essential Structures Damaged $<$ 30%  | 2               |
| 20% $\leq$ Ratio of Essential Structures Damaged $<$ 25%  | 3               |
| 10% $\leq$ Ratio of Essential Structures Damaged $<$ 20%  | 4               |
| Ratio of Essential Structures Damaged $<$ 10%   | 5               |
| Consequence Category 5 Rating Criteria  | Category Rating |
| <b>Legal Mandate (Federal):</b> Federal Law dictates closure or suspension of the project operations                          | 1               |
| Financial penalties or criminal liabilities imposed but do not impact the operations of the project.                          | 2               |
| Legal Mandates issues are based solely on State or Local statutes   | 3               |
| No Legal Mandate exists   | 4               |
| No Legal Mandate exists   | 5               |
| Consequence Category 6 Rating Criteria  | Category Rating |
| <b>Social Vulnerability:</b> Population over 65 $\geq$ 30%  | 1               |
| 25% $\leq$ Population over 65 $<$ 30%   | 2               |
| 20% $\leq$ Population over 65 $<$ 25%   | 3               |
| 10% $\leq$ Population over 65 $<$ 20%   | 4               |
| Population over 65 $<$ 10%  | 5               |
| Consequence Category 7 Rating Criteria  | Category Rating |
| <b>Historic:</b> Massive losses to historic or culturally significant sites ( $\geq$ \$1B)                                    | 1               |
| Major losses to historic or culturally significant sites (\$10M-\$1B)   | 2               |
| Moderate losses to historic or culturally significant sites (\$1M-\$10M)  | 3               |
| Minor losses to historic or culturally significant sites ( $<$ \$1M)  | 4               |
| No historical or culturally significant properties impacted   | 5               |
| Consequence Category 8 Rating Criteria  | Category Rating |
| <b>Coastal Projects:</b> Highest economic impact $\geq$ \$100M  | 1               |
| High economic impact \$10M - \$100M   | 2               |
| Moderate economic impact \$1M - \$10M   | 3               |
| Low economic impact $<$ \$1M  | 4               |
| No economic impact  | 5               |



# The Pieces of the Puzzle

## Assigning Condition Ratings



### Condition Rating Logic

|            | REMARKS   | CONDITION RATING | DEFINITION   |
|------------|---|------------------|--|
| STRUCTURAL | A. The component is structurally sound and meeting the design intent of the manufacturer and the design engineer. | EXCELLENT        | EXCELLENT: The component is in good condition and meets the design intent of the manufacturer and the design engineer.               |
| PAVEMENT   | A. There is no visible deterioration or damage to the pavement surface.   | GOOD             | GOOD: The pavement is in good condition and meets the design intent of the manufacturer and the design engineer.                     |
| PAVEMENT   | B. There is no visible deterioration or damage to the pavement surface.   | FAIR             | FAIR: The pavement is in fair condition and meets the design intent of the manufacturer and the design engineer.                     |
| PAVEMENT   | C. There is visible deterioration or damage to the pavement surface.  | POOR             | POOR: The pavement is in poor condition and meets the design intent of the manufacturer and the design engineer.                     |
| PAVEMENT   | D. There is severe deterioration or damage to the pavement surface.   | UNSATISFACTORY   | UNSATISFACTORY: The pavement is in unsatisfactory condition and meets the design intent of the manufacturer and the design engineer. |
| PAVEMENT   | E. There is a total failure of the pavement surface.  | UNSATISFACTORY   | UNSATISFACTORY: The pavement is in unsatisfactory condition and meets the design intent of the manufacturer and the design engineer. |

**Consistent and Repeatable Process!**

**BUILDING STRONG.**

- Operational Condition Assessments (OCA) developed by IMTS BPR group, approved by IMTS BoD and implemented by MSC Teams


- Economic Consequences on Shippers and Carriers (varying durations, 1-365 days) from Planning Center of Expertise for Inland Navigation (PCXIN)

$$\text{Probability of Operational Failure} \times \text{Consequence of Failure}$$

(Unsatisfactory Performance)

### 1. Correlate OCA

- Baseline Probability of Failure [P(f)] curves developed by Risk Management Center with support from MSC SME's



| Condition Rating | Numeric Condition Value | Surregare Probability of Failure/Reliability |
|------------------|-------------------------|--|
| Complete Failure | 10                      | 1  |
| F                | 9.325                   | .9325  |
| F-               | 7.965                   | .7795  |
| Fo               | 6.665                   | .6665  |
| F+               | 5.675                   | .5675  |
| D-               | 5.005                   | .5005  |
| D                | 4.335                   | .4335  |
| D+               | 3.575                   | .3575  |
| C-               | 2.745                   | .2745  |
| C                | 1.915                   | .1915  |
| C+               | 1.325                   | .1325  |
| B-               | 0.995                   | .0995  |
| B                | 0.665                   | .0665  |
| B+               | 0.417                   | .0417  |
| A                | 0                       | 0  |

**BUILDING STRONG®**

OCA

 $P(f)$ 

## Recovery Durations

- Baseline “Recovery Durations” to restore Mission after an Unscheduled Outage due to a Critical Component Failure

|   | Importance Factors |        | Impact Resource Factors |                |                |                   |
|---|--------------------|--------|-------------------------|----------------|----------------|-------------------|
|   | Neutral            | Unsure | Minor Economy           | Stable Economy | Robust Economy | Southwest Economy |
| <b>PI/Empty Values</b>  |                    |        |                         |                |                |                   |
| Values: Value structures of various types that include relevant services, services, security, travel, agricultural, financial, ability, storage and others are affected | 35                 | 17     | 0                       | 7              | 1              | 0                 |
|   | 53.5               | 21     | 1.20                    | 7              | 4.20           | 0                 |
|   | 40                 | 20     | 0                       | 0              | 0              | 0                 |
|   | 30                 | 9      | 0                       | 0              | 0              | 0                 |
|   | 75                 | 50     | 7                       | 7              | 7              | 40                |
| Mean Value  | 52.5               | 30.6   |                         |                | 5.6            |                   |
| Standard Deviation  | 8.46               | 31.06  |                         |                |                |                   |

|                    | 70   | 8     | 0    | 7   | 1  |
|--------------------|------|-------|------|-----|----|
| ing embedded       | 53.5 | 11    | 1.25 | 7   | 41 |
| stents at the      | 67   | 75    | 10   | 7   | 6  |
| at the structure   | 55   | 0     | 0    | 0   | 0  |
|                    | 70   | 50    | 16   | 7   | 60 |
| Mean Value         | 62.9 | 29.8  |      | 5.6 |    |
| Standard Deviation | 8.49 | 32.26 |      |     |    |
|                    | 70   | 80    | 1    | 5   | 1  |
| is equipment       | 53.5 | 22.5  | 1.25 | 9   | 22 |
| guides,            | 67   | 75    | 10   | 80  | 6  |
| ing or pulling     | 55   | 0     | 0    | 0   | 0  |
|                    | 60   | 50    | 5    | 7   | 6  |

| Mean Value         | 60.9 | 35.5  | 5 |
|--------------------|------|-------|---|
| Standard Deviation | 7.32 | 28.42 |   |

| equipped with such<br>a and hydraulic<br>to main | 39 | 30 | 1    | 5  | 1   |
|--|----|----|------|----|-----|
|  | 53 | 16 | 1.25 | 9  | 4.1 |
|  | 67 | 75 | 10   | 90 | 6   |
|  | 55 | 0  | 0    | 0  | 1   |
|  | 60 | 50 | 1    | 7  | 30  |

|   | Mean Value         | 61    | 34.2  |   | 5   |
|---|--------------------|-------|-------|---|-----|
|   | Standard Deviation | 7.38  | 29.30 |   |     |
| <b>5. Value Operating Equipment - Electrical</b>  |                    |       |       |   |     |
| Reliable: At present electrical components of the value operating equipment such as electric motors, motor spares, cabling, power and control conductors. | 70                 | 80    | 1     | 0 | 1   |
|   | 65.6               | 76    | 1.25  | 0 | 1.2 |
|   | 67                 | 75    | 0     | 0 | 0   |
|   | 65                 | 76    | 0     | 0 | 0   |
|   | 60                 | 80    | 1     | 7 | 30  |
|   | Mean Value         | 68.9  | 69.4  |   | 1.8 |
|   | Standard Deviation | 10.30 | 20.72 |   |     |
| <b>6. Miscellaneous Value Equipment</b>   |                    |       |       |   |     |

*the IMTS!!*



**BUILDING STRONG®**

*All of this for 166,000 asset components across the IMTS!!*

# OCA and ORA

- AM needed methodology to estimate the probability of failure for Operational Risk Assessment (ORA) processes
- AM required the development of a relationship between both Operational Condition Assessment (OCA) data and the estimate of the probability of failure
  - ▶ Utilize state-of-practice and state-of-the-art models and methods to map OCA to Pf





# Development of Baseline Weibull Curves

- Initial estimate of OCA to probability of failure translation for predefined set of components by major categories
- Estimated probabilities of failure using Expert-Opinion Elicitation
  - ▶ Navigation SME/RTS from USACE Districts nationwide
  - ▶ Real-time processing data to Weibull curves for experts input and review




# Development of Baseline Weibull Curves

- Estimate OCA and Pf transitions based on statistical estimation of the Maximum Likelihood Estimator (MLE) properties of Weibull Distributions
  - ▶ Translations can be adjusted as age and condition are defined by OCA resulting in updated Pf
- As additional OCA and failure data are collected Bayesian updating process can be utilized to modify and adjust baseline Weibull parameters
  - ▶ Permits more accurate estimation of Pf as additional data is collected and processed




# Expert-Opinion Elicitation



# Calculating Operational Risk (ORA)

## Probability of Operational Failure X Consequence of Failure (Unsatisfactory Performance)

What is the **Condition** of Components in your site specific Inventory? and based on the condition of THAT Component what is its **Probability of Failure**?



What is the average "Impact **Recovery Duration**" (in DAYS) to **restore Mission** capability for that component from a failure that caused an **Unscheduled Outage**?

What **Economic impact** on **Shippers-Carriers** is there based on the Duration of that **Unscheduled Outage**?

Component "X" has an IRD = 20 days

Notional Example:

**Component "X" in Condition "D"**  
Has  $P(f) = 0.488996058$

$$P(f) \times \text{Consequence} = \text{Risk}$$

$$0.488996058 \times \$2,663,000 = \$1,302,197$$

At L&D Site "Y" the Econ Impact on Shippers-Carriers for an Unscheduled Outage of 20 days = \$2,663K



**BUILDING STRONG®**

# USACE AM Total Risk Exposure (TRE)


For EACH IMTS Site (to Component level):

Inventory Condition P(f) X


Econ Impact on Shippers and Carriers = Risk (@ Component level)

X

$\Sigma = \text{TRE}$



## Assigning Condition Ratings



| Rating | Definition |
|--------|------------|
| A      | Excellent  |
| B      | Good       |
| C      | Fair       |
| D      | Poor       |
| F      | Failure    |

Consistent and Repeatable Process!

BUILDING STRONG®

Total Risk Exposure is composed of:

**“Residual Risk”** – Components in “A” & “B” condition that *currently* do NOT show impacts on mission performance (including components that have been Repaired/Replaced)

**“Operational Risk”** – Components in “C” thru “F” condition that *currently* show impacts on mission performance

Each IMTS Site will have varying degrees of Operational and Residual Risk which can inform Investment Strategies



BUILDING STRONG®



# Operational Risk Exposure – Feature | System

(Condition/Risk of Critical Components across entire IMTS)

## Feature | System

| Feature   System                              | Operational Risk Exposure (\$K) | Residual Risk AFTER Repair (\$K) |
|---|---------------------------------|----------------------------------|
| ▼ Dam   | \$1,004,913                     | \$165,124                        |
| ▶ Dam Gates & Operating Machinery             | \$538,761                       | \$79,510                         |
| ▶ Dam Structures                              | \$466,152                       | \$85,614                         |
| ▼ Lock  | \$2,208,032                     | \$304,897                        |
| ▶ Lock Filling and Emptying Systems           | \$64,109                        | \$8,181                          |
| ▶ Lock Gates & Operating Machinery            | \$600,950                       | \$77,625                         |
| ▶ Lock Structure                              | \$1,542,973                     | \$219,091                        |
| ▼ Miscellaneous Support Structures & Systems  | \$12,321                        | \$1,533                          |
| ▶ Emergency Maintenance & Closure System      | \$9,095                         | \$878                            |
| ▶ Lock & Dam Bridges                          | \$3,226                         | \$655                            |
| ▼ Utilities/Power/Controls                    | \$19,276                        | \$3,633                          |
| ▶ Controls, Indicators, Interlocks & PLC's    | \$5,856                         | \$1,255                          |
| ▶ Primary Utilities Distribution & Controls   | \$13,386                        | \$2,374                          |
| ▶ Secondary Utilities Distribution & Controls | \$35                            | \$5                              |
| Grand Total                                   | \$3,244,542                     | \$475,188                        |

## Feature | System | Sub-System | Component

|   |             |           |
|---|-------------|-----------|
| ▼ Lock  | \$2,208,032 | \$304,897 |
| ▶ Lock Filling and Emptying Systems                   | \$64,109    | \$8,181   |
| ▼ Lock Gates & Operating Machinery                    | \$600,950   | \$77,625  |
| ▼ Lock Gate Anchorages & Support Features             | \$185,598   | \$21,384  |
| Lift Gate Anchorage                                   | \$11,591    | \$1,742   |
| Miter Gate Anchorage                                  | \$147,027   | \$15,995  |
| Sector Gate Anchorage                                 | \$26,134    | \$3,571   |
| Tainter Gate Anchorage                                | \$847       | \$76      |
| ▼ Lock Gate Operating Equipment                       | \$46,220    | \$7,256   |
| Chain Hoist Mechanism (Electric)                      | \$649       | \$187     |
| Direct Acting Hydraulic Cylinder                      | \$1,931     | \$344     |
| Electrical Operating Equipment (Lock Gates)           | \$5,345     | \$1,360   |
| Ohio River Type Assembly (Electric)                   | \$1,765     | \$333     |
| Ohio River Type Assembly (Hydraulic)                  | \$27,453    | \$3,725   |
| Packaged Direct Connected Hydraulic Cylinder Assembly | \$117       | \$21      |
| Panama Type Assembly (Electric)                       | \$4,857     | \$860     |
| Rope Hoist Mechanism (Electric)                       | \$1,269     | \$217     |
| Rope Hoist Mechanism (Hydraulic)                      | \$2,779     | \$207     |
| Wire Rope Cable (Horizontal Pull) Assembly            | \$53        | \$3       |
| ▼ Lock Gate Structures                                | \$189,876   | \$29,112  |
| Miter Type Gate                                       | \$133,404   | \$19,814  |
| Sector Type Gate                                      | \$19,016    | \$4,814   |
| Tainter Type Gate                                     | \$2,146     | \$352     |
| Vertical Lift Type Gate                               | \$35,310    | \$4,131   |
| ▼ Misc Lock Gate Features                             | \$179,256   | \$19,873  |
| Miter Guide   | \$1         | \$0       |
| Pintles   | \$60,238    | \$8,496   |
| Quoin Blocks & Other Load Blocks                      | \$119,016   | \$11,377  |

*Notional Working Draft Pre-decisional Example*


*Maintain and Repair the Most Critical Components that have the Potential to Cause Highest Mission Impacts*



**BUILDING STRONG®**



# Life Cycle Investment Strategies



Report of PIANC Working Group 25 InCom

8

Fig. 1

InCom\_ReportWG25.indd 8

28/03/2006 10:12:37

*Risk Exposure assists in informing Life Cycle Investment Decisions*



**BUILDING STRONG®**

# Budget Prioritization

## ➤ AMPA tool - FRM, NAV, and HYD

- AMPA Technical Documentation (2015) - Details regarding specific business line data, value model design and process
- Very important to enter accurate data in CWIFD and complete all the fields
- Available on the AMPA SharePoint site, folder called AMPA Budget Tools-AMPA-FY18 Budget Development folder:

<https://cops.usace.army.mil/sites/AM/PA/AMPA%20Budget%20Tools/Forms/AllItems.aspx>


- Or at the AM Tools site under the “AMPA Workbook Tools and Download (NAV, FRM, HYD)” link at:

<https://assetmanagement.usace.army.mil/tools/>

## ➤ AMPA tool - Demonstration



## Consequences



**CWIFD**  
**Column 34**  
(Prior Consequence  
Category from 5x5)




| Consequence Category | Consequence Rating Criteria   |
|----------------------|---|
| I                    | <p><b>High:</b></p> <ul style="list-style-type: none"> <li>- Public or Life Safety Impact and/or</li> <li>- Violation of Legal Requirement(s) and/or</li> <li>- Forced Outage /Closure resulting in Highest Economic Loss and/or</li> <li>- Greatest Decrease in Performance (e.g., efficiency, capacity, reliability) and/or</li> <li>- Greatest Increase in Life Cycle Costs and/or</li> <li>- Greatest Increase in Critical Maintenance Backlog</li> </ul> |
| II                   | <p><b>Medium-High:</b></p> <ul style="list-style-type: none"> <li>- Forced Outage / Closure resulting in High Economic Loss and/or</li> <li>- Great Decrease in Performance (e.g., efficiency, capacity, reliability) and/or</li> <li>- Great Increase in Life Cycle Costs and/or</li> <li>- Great Increase in Critical Maintenance Backlog</li> </ul>  |
| III                  | <p><b>Medium:</b></p> <ul style="list-style-type: none"> <li>- Forced Outage/Closure resulting in Moderate Economic Loss and/or</li> <li>- Moderate Decrease in Performance (e.g., efficiency, capacity, reliability) and/or</li> <li>- Moderate Increase in Life Cycle Costs and/or</li> <li>- Moderate Increase in Critical Maintenance Backlog</li> </ul>  |
| IV                   | <p><b>Low:</b></p> <ul style="list-style-type: none"> <li>- Forced Outage/Closure resulting in Minor Economic Loss and/or</li> <li>- Minor Decrease in Performance (e.g., efficiency, capacity, reliability) and/or</li> <li>- Minor Increase in Life Cycle Costs and/or</li> <li>- Minor Increase in Critical Maintenance Backlog</li> </ul>   |
| V                    | <p><b>Minimal:</b></p> <ul style="list-style-type: none"> <li>- Forced Outage/Closure resulting in Minimal Economic Loss and/or</li> <li>- Minimal Decrease in Performance (e.g., efficiency, capacity, reliability) and/or</li> <li>- Minimal Increase in Life Cycle Costs and/or</li> <li>- Minimal Increase in Critical Maintenance Backlog</li> </ul>   |

| Decision Model Variable          | Data Source                  |
|----------------------------------|------------------------------|
| $V(\text{Fund}, F)$              | $V_{\text{hyd}}(\mathbf{x})$ |
| $V(\sim \text{Fund}, F)$         | CWIFD Column 34              |
| $\text{Pr}(\text{Fund}, F)$      | CWIFD Column 37              |
| $\text{Pr}(\sim \text{Fund}, F)$ | CWIFD Column 33              |

$$x_1, \dots, x_6) = \sum_i^6 w_i v_i(x_i), \quad (1)$$

| Work Package ID | Value Difference | Cost    | Cumulative Cost | Cumulative Value | Value Ratio | Work Package Title                    | District Rank | MSC Rank | AMPA Rank | Increment | Program Name                   |
|-----------------|------------------|---------|-----------------|------------------|-------------|---------------------------------------|---------------|----------|-----------|-----------|--------------------------------|
| 9365            | 0.063888889      | 40000   | 40000           | 0.063888889      | 1.59722E-06 | Erosion Repair on Dam Embankment      | 200           | -        | 1         | 4.5       | SAM RAYBURN DAM AND RESERVOIR  |
| 110434          | 0.063888889      | 80000   | 120000          | 0.127777778      | 7.98611E-07 | Replace Wire Ropes on Flood Gate      | 241           | -        | 2         | 4.5       | SAM RAYBURN DAM AND RESERVOIR  |
| 24220           | 0.083333333      | 125000  | 245000          | 0.211111111      | 6.66667E-07 | Repair Training Wall                  | 1230          | -        | 3         | 4.5       | GREERS FERRY LAKE, AR          |
| 43275           | 0.083333333      | 153000  | 398000          | 0.294444444      | 5.44662E-07 | Replace Roadway Median Hatch Cover    | 1070          | -        | 4         | 3.5       | NORFORK LAKE, AR               |
| 21571           | 0.225            | 500000  | 898000          | 0.519444444      | 0.00000045  | FY18 NRW Repair Crack in Spillway     | 17            | -        | 5         | 3.5       | KAW LAKE, OK                   |
| 92554           | 0.073611111      | 165000  | 1063000         | 0.593055556      | 4.46128E-07 | Replace Dam Main Power Switchgear     | 1130          | -        | 6         | 4.5       | NIMROD LAKE, AR                |
| 48258           | 0.052777778      | 150000  | 1213000         | 0.645833333      | 3.51852E-07 | Rehabilitate Surface Drainage         | 177           | -        | 7         | 4.5       | WRIGHT PATMAN DAM AND LAKE, TX |
| 9531            | 0.05             | 150000  | 1363000         | 0.695833333      | 3.33333E-07 | Pave west abutment access road        | 287           | -        | 8         | 5.5       | TOWN BLUFF DAM, B A STEINHAGEN |
| 90954           | 0.083333333      | 250000  | 1613000         | 0.779166667      | 3.33333E-07 | Repair Right Training Wall            | 1170          | -        | 9         | 4.5       | BEAVER LAKE, AR                |
| 9008            | 0.077777778      | 250000  | 1863000         | 0.856944444      | 3.11111E-07 | Hardwire Low Flow Controllers         | 237           | -        | 10        | 4.5       | GRAPEVINE LAKE, TX             |
| 57294           | 0.030555556      | 100000  | 1963000         | 0.8875           | 3.05556E-07 | 2015 Flood Event Class II: Upstream   | 209           | -        | 11        | 4.5       | LAVON LAKE, TX                 |
| 103774          | 0.070833333      | 235000  | 2198000         | 0.958333333      | 3.01418E-07 | Replace Wet Well Balancing Valves     | 181           | -        | 12        | 4.5       | BELTON LAKE, TX                |
| 25928           | 0.288888889      | 1250000 | 3448000         | 1.247222222      | 2.31111E-07 | DSPMT SWD# 3.036 SWG#3.001 Repair     | 35            | -        | 13        | 3.5       | BUFFALO BAYOU AND TRIBUTARIES  |
| 103734          | 0.070833333      | 350000  | 3798000         | 1.318055556      | 2.02381E-07 | Replace Overhead Crane Hoist Cable    | 175           | -        | 14        | 4.5       | BELTON LAKE, TX                |
| 99654           | 0.083333333      | 500000  | 4298000         | 1.401388889      | 1.66667E-07 | Clear Vegetation from Toe of Dam      | 1260          | -        | 15        | 4.5       | GREERS FERRY LAKE, AR          |
| 43335           | 0.104166667      | 625000  | 4923000         | 1.505555556      | 1.66667E-07 | Replace Sluice Gate Wiring, Sump      | 1050          | -        | 16        | 3.5       | TABLE ROCK LAKE, MO & AR       |
| 48397           | 0.036111111      | 245000  | 5168000         | 1.541666667      | 1.47392E-07 | Replace Riprap                        | 182           | -        | 17        | 4.5       | NAVARRO MILLS LAKE, TX         |
| 25925           | 0.288888889      | 2170000 | 7338000         | 1.830555556      | 1.33129E-07 | Rehabilitation Clodine Ditch Phase    | 48            | -        | 18        | 4.5       | BUFFALO BAYOU AND TRIBUTARIES  |
| 23372           | 0.094444444      | 798000  | 8136000         | 1.925            | 1.18351E-07 | Dewater and Repair Stilling Basin     | 1280          | -        | 19        | 4.5       | CLEARWATER LAKE, MO            |
| 9540            | 0.063888889      | 582000  | 8718000         | 1.988888889      | 1.09775E-07 | Repair Shoreline Erosion              | 126           | -        | 20        | 3.5       | SAM RAYBURN DAM AND RESERVOIR  |
| 23036           | 0.030555556      | 300000  | 9018000         | 2.019444444      | 1.01852E-07 | Rebuild Tainter Gate Break            | 180           | -        | 21        | 4.5       | LAVON LAKE, TX                 |
| 110754          | 0.070833333      | 750000  | 9768000         | 2.090277778      | 9.44444E-08 | Repair Cracked Service Gate           | 125           | -        | 22        | 3.5       | BELTON LAKE, TX                |
| 9320            | 0.045833333      | 539000  | 10307000        | 2.136111111      | 8.5034E-08  | Replace Hydraulic Pump Unit on Sluice | 187           | -        | 23        | 4.5       | WHITNEY LAKE, TX               |
| 112375          | 0.076388889      | 950000  | 11257000        | 2.2125           | 8.04094E-08 | DSPMT SWD# 3.098 SWG# 3.006 Repair    | 41            | -        | 24        | 4.5       | WALLISVILLE LAKE, TX           |
| 23090           | 0.077777778      | 1000000 | 12257000        | 2.290277778      | 7.77778E-08 | Replace Four Emergency Slide Gate     | 163           | -        | 25        | 3.5       | GRAPEVINE LAKE, TX             |
| 9299            | 0.163888889      | 2500000 | 14757000        | 2.454166667      | 6.55556E-08 | Phase 3 Repair Tainter Gates          | 198           | -        | 26        | 4.5       | WACO LAKE, TX                  |







# Conclusions

- Over the past 25 years, USACE has invoked many different risk assessment methodologies for use in their risk-informed decision making processes.
- Each risk assessment methodology has their particular benefits and drawbacks
- Risk assessment methodologies are not static but dynamic and change with the next generations



**and THIS, ladies and gentlemen, is how a Twinkie is made. Any questions?**

